

Message

From: **Ex. 4 CBI** [redacted]@TechLawInc.com]
Sent: 8/10/2018 5:56:25 PM
To: Matlock, Dennis [Matlock.Dennis@epa.gov]
Subject: RE: Newest PCE Test Results

Dennis,

There is obviously a source area that is affecting the city's water wells. If they have a suspected source area (former dry cleaner, etc.), we could always do an assessment and do some Geoprobings in the area and collect soil and groundwater near the source area to determine if it actually is the source. If it is, by addressing the source area, the impacts to city wells could be alleviated.

Ex. 4 CBI

TechLaw, Inc.
Wheeling, WV Office
740-867-0968 (Office)
304-830-1442 (Mobile)

From: Matlock, Dennis [mailto:Matlock.Dennis@epa.gov]
Sent: Friday, August 10, 2018 12:13 PM
To: Huggins, William <William.Huggins@wv.gov>
Cc: **Ex. 4 CBI** [redacted]@TechLawInc.com>
Subject: FW: Newest PCE Test Results

From: Towle, Michael
Sent: Friday, September 29, 2017 7:08 AM
To: Matlock, Dennis <Matlock.Dennis@epa.gov>
Subject: Fwd: Newest PCE Test Results

FYI. Public water just fine.

Sent from my iPhone

Begin forwarded message:

From: Josh Billiter <josh.billiter.padencity@gmail.com>
Date: September 29, 2017 at 7:02:58 AM EDT
To: Lewis Baker <lew baker@wvrwa.org>, "Smith, Bob A" <Bob.A.Smith@wv.gov>, Towle.michael@epa.gov
Subject: Newest PCE Test Results

Got new testing results from Sept 14, 2017

Raw Water (pre stripper)	8.16
Finished Water (post stripper)	0.380
Public Sites	
53 Carmen Ln	0.410

310 South 4th Ave

0.500

If my math is correct we are removing 95% of the contaminant through the air stripping process.

Just a wanted to let everyone know where we stand at this moment. Will be testing again in October hopefully more of the same, but time will tell.

Thanks

Josh Billiter

Paden City Water Works